



PRODUCT PERFORMANCE REPORT

Document ID 1474964609

Issued on September 27th, 2016

PROJECT IDENTIFICATION - This product performance report is delivered for:

Name **Dainius**
 Company **UAB Daikaras**
 Project reference **ERLQ008CV3/EHBX08CB**
 Project location **Lithuania**

PRODUCT IDENTIFICATION

Certification Diploma N° **97.01.107**
 Brand **DAIKIN**
 Range **ERLQ-CV3 + EHBX-CB**
 Product reference **ERLQ008CV3/EHBX08CB**

Important notice:

- I. Data featured in this report are valid at the date of issue. The scope of this product performance report does not include all certified data that can be checked at <http://www.eurovent-certification.com>
- II. This product performance report is valid only for above product features and should not be referred to as a Diploma.

FEATURE	VALUE	UNIT
Acoustics - Cooling		
LwO	62.0	dB(A)
Air Conditioning		
Pc	5.36	kW
Pec	2.34	kW
EER	2.29	
Ph	6.89	kW
Peh	2.01	kW
COP	3.42	
Class EER	F	
Cooling Floor		
Pc	6.2	kW
Pec	1.64	kW
EER	3.79	
General		
MPS	230-1-50	
Refrigerant	R410A	
Heating Floor		
Ph	7.4	kW
Peh	1.66	kW
COP @ 7	4.45	
Class COP	A	
Seasonal Efficiency for Heating - Average - Low T.		
Pdesignh Average W35	40.0	kW
SCOP Average W35	4.34	



PRODUCT PERFORMANCE REPORT

Document ID 1474964609

Issued on September 27th, 2016

FEATURE	VALUE	UNIT
η_s Average W35	171.0	%
Seasonal Efficiency for Heating - Average - Med T.		
$P_{designh}$ Average W55	6.4	kW
SCOP Average W55	3.23	
η_s Average W55	126.0	%