



PRODUCT PERFORMANCE REPORT

Document ID 1463038815

Issued on May 12th, 2016

PROJECT IDENTIFICATION - This product performance report is delivered for:

Name **Daikaras**
 Project reference
 Project location **Lithuania**

PRODUCT IDENTIFICATION

Certification Diploma N° **94.01.135**
 Brand **TOSHIBA**
 Range **DSK6**
 Product reference **RAS-35SAVP2-ND/RAS-35SKVP2-ND**

Important notice:

I. Data featured in this report are valid at the date of issue. The scope of this product performance report does not include all certified data that can be checked at <http://www.eurovent-certification.com>

II. This product performance report is valid only for above product features and should not be referred to as a Diploma.

FEATURE	VALUE	UNIT
Acoustic		
LwO env	63	dB(A)
Lw1 env	58	dB(A)
Cooling		
Pdesignc	3.52	kW
SEER	6.8	
SEER Class	A++	
Qce	180.0	kWh/y
EER @+35	4.19	
General		
Mounting	HighWall	
MPS	230-1-50	
Refr. Line	5m	m
Refrigerant	R410a	
Heating		
Pdesignh	3.5	kW
SCOP	4.0	
SCOP Class	A+	
Qhe	1225.0	kWh/y
Tbiv	-7	C
Ph @Tbiv	3.1	kW
COP @Tbiv	2.55	
TOL	-20.0	C
Ph @ TOL	1.75	kW
COP @TOL	1.85	
Ph @+7	4.22	kW



PRODUCT PERFORMANCE REPORT

Document ID 1463038815

Issued on May 12th, 2016

FEATURE	VALUE	UNIT
COP @+7	4.44	
Power input in other modes		
Poff	9.0	W
Psb	9.0	W
Pto	26.0	W