PRODUCT PERFORMANCE REPORT

Document ID 1463047599
Issued on May 12th, 2016

PROJECT IDENTIFICATION

- This product performance report is delivered for:

Name	**Daikaras**
Project reference	
Project location	**Lithuania**

PRODUCT IDENTIFICATION

Certification Diploma N°	**94.01.087**
Brand	**DAIKIN**
Range	**RXL**
Product reference	**RXL25M3 / FVXS25F**

Important notice:

I. Data featured in this report are valid at the date of issue. The scope of this product performance report does not include all certified data that can be checked at http://www.eurovent-certification.com

II. This product performance report is valid only for above product features and should not be referred to as a Diploma.

FEATURE	VALUE	UNIT
Acoustic		
LwO env	61	dB(A)
LwI1 env	52	dB(A)
Cooling		
Pdesignc	2.5	kW
SEER	5.1	
SEER Class	A	
Qce	173.0	kWh/y
EER @+35	3.38	
General		
Mounting	Wall	
MPS	230/1/50	
Refr. Line	5 m	m
Refrigerant	R-410A	
Heating		
Pdesignh	3.2	kW
SCOP	4.04	
SCOP Class	A+	
Qhe	1109.0	kWh/y
Tbiv	-7	C
Ph @Tbiv	3.2	kW
COP @Tbiv	2.42	
TOL	-15.0	C
Ph @ TOL	2.11	kW
COP @TOL	2.31	
Ph @+7	4.5	kW

PRODUCT PERFORMANCE REPORT

Document ID 1463047599
Issued on May 12th, 2016

FEATURE	VALUE	UNIT
COP @+7	3.78	
Power input in other modes		
Poff	15.0	W
Psb	15.0	W
Pto	40.0	W