



# PRODUCT PERFORMANCE REPORT

Document ID 1462970057

Issued on May 11th, 2016

## PROJECT IDENTIFICATION - This product performance report is delivered for:

Name **Daikaras**  
 Project reference  
 Project location **Lithuania**

## PRODUCT IDENTIFICATION

Certification Diploma N° **94.01.087**  
 Brand **DAIKIN**  
 Range **RXZ**  
 Product reference **RXZ35N / FTXZ35N**

### Important notice:

- I. Data featured in this report are valid at the date of issue. The scope of this product performance report does not include all certified data that can be checked at <http://www.eurovent-certification.com>
- II. This product performance report is valid only for above product features and should not be referred to as a Diploma.

FEATURE	VALUE	UNIT
<b>Acoustic</b>		
LwO env	61	dB(A)
Lw1 env	57	dB(A)
<b>Cooling</b>		
Pdesignc	3.5	kW
SEER	9.0	
SEER Class	A+++	
Qce	136.0	kWh/y
EER @+35	5.3	
<b>General</b>		
Mounting	Wall	
MPS	230/1/50	
Refr. Line	5 m	m
Refrigerant	R32	
<b>Heating</b>		
Pdesignh	4.5	kW
SCOP	5.73	
SCOP Class	A+++	
Qhe	1100.0	kWh/y
Tbiv	-7	C
Ph @Tbiv	3.98	kW
COP @Tbiv	3.91	
TOL	-15.0	C
Ph @ TOL	2.94	kW
COP @TOL	3.25	
Ph @+7	5.0	kW



# PRODUCT PERFORMANCE REPORT

Document ID 1462970057

Issued on May 11th, 2016

FEATURE	VALUE	UNIT
COP @+7	5.0	
<b>Power input in other modes</b>		
Poff	1.0	W
Psb	1.0	W
Pto	6.0	W