



# PRODUCT PERFORMANCE REPORT

Document ID 1462970166

Issued on May 11th, 2016

**PROJECT IDENTIFICATION** - This product performance report is delivered for:

Name **Daikaras**  
 Project reference  
 Project location **Lithuania**

**PRODUCT IDENTIFICATION**

Certification Diploma N° **94.01.087**  
 Brand **DAIKIN**  
 Range **RXZ**  
 Product reference **RXZ50N / FTXZ50N**

Important notice:

- I. Data featured in this report are valid at the date of issue. The scope of this product performance report does not include all certified data that can be checked at <http://www.eurovent-certification.com>
- II. This product performance report is valid only for above product features and should not be referred to as a Diploma.

FEATURE	VALUE	UNIT
<b>Acoustic</b>		
LwO env	63	dB(A)
Lw1 env	60	dB(A)
<b>Cooling</b>		
Pdesignc	5.0	kW
SEER	8.6	
SEER Class	A+++	
Qce	203.0	kWh/y
EER @+35	4.55	
<b>General</b>		
Mounting	Wall	
MPS	230/1/50	
Refr. Line	5 m	m
Refrigerant	R32	
<b>Heating</b>		
Pdesignh	5.6	kW
SCOP	5.5	
SCOP Class	A+++	
Qhe	1427.0	kWh/y
Tbiv	-7	C
Ph @Tbiv	4.95	kW
COP @Tbiv	3.82	
TOL	-15.0	C
Ph @ TOL	3.97	kW
COP @TOL	2.98	
Ph @+7	6.3	kW



# PRODUCT PERFORMANCE REPORT

Document ID 1462970166

Issued on May 11th, 2016

FEATURE	VALUE	UNIT
COP @+7	4.47	
<b>Power input in other modes</b>		
Poff	1.0	W
Psb	1.0	W
Pto	6.0	W